

# Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Bloom & Grow Academy**

City: **Harrisburg**

Provider Number: **018043120**

Inspector: **Sarah Boese**

Date of Inspection: **07/17/2024**

Time of Inspection: **1:04 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. Fire and Life Safety

21. Are portable fire extinguishers charged, operable, and inspected annually by a qualified service technician? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made:	Agency Action:
<b>A qualified service technician had yet to inspect the portable fire extinguishers.</b>	<b>Compliance Plan</b>
<b>The portable fire extinguishers must be inspected annually by a qualified service technician.</b>	Suggested Completion Date: <b>07/27/2024</b>
<b>Correction: The provider provided documentation that a qualified service technician inspected the portable fire extinguishers.</b>	Actual Completion Date: <b>07/22/2024</b>
	Status: <b>Corrected</b>

**Sara Robinson**

Provider Signature

**07/17/2024**

Date

**Sarah Boese**

Inspector Signature

**07/17/2024**

Date