

Family Day Care Inspection Compliance Plan

Provider's Name: **Jamie Owsley**

City: **Sioux Falls**

Provider Number: **018043123**

Inspector: **Stacie Ugofsky**

Date of Inspection: **01/10/2023**

Time of Inspection: **12:05 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. Record Keeping/Fire Safety & Emergency Weather Drills

30. Does each child's record contain all required information? 67:42:16:13

Corrections To Be Made:

**AD - Emergency Permission
LT - Emergency Permission**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/15/2023

Actual
Completion
Date:

01/13/2023

Status: **Corrected**

C. Health & Safety Features of the Home - Indoor Environmental Observations

61. Is there a fully charged, portable fire extinguisher, with minimum 2A rating, kept near the food prep area? 67:42:03:11.02

Corrections To Be Made:

The fire extinguisher present at the time of the inspection is 1A rated.

The fire extinguisher must be 2A rated, fully charged and kept in the kitchen prep area.

Correction: A 2A fire extinguisher was obtained and stored in the food prep area.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

01/15/2023

Actual
Completion
Date:

01/11/2023

Status: **Corrected**

Jamie Owsley

Provider Signature

01/10/2023

Date

Stacie Ugofsky

Inspector Signature

01/10/2023

Date