

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Pulse of Life Kids Care**

City: **Vermillion**

Provider Number: **018043136**

Inspector: **Stacy Wildermuth**

Date of Inspection: **11/18/2024**

Time of Inspection: **10:00 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

7. In Licensed Programs caring for 21 or More Children - If a fire sprinkler system is present, is it inspected and serviced annually by a qualified service technician? 61:15:01:01

Corrections To Be Made:

Fire sprinkler system was last inspected 9/26/23.

Sprinkler system should be inspected annually.

***Correction: updated inspection document received.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

12/15/2024

Actual
Completion
Date:

12/05/2024

Status: **Corrected**

Glenn Pulse

Provider Signature

11/18/2024

Date

Stacy Wildermuth

Inspector Signature

11/18/2024

Date