

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **JFK ELEMENTARY CLC**

City: **Sioux Falls**

Provider Number: **018043138**

Inspector: **Todd Lowe**

Date of Inspection: **08/23/2023**

Time of Inspection: **2:35 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

17. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05; 61:15:06:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

Room 228 did not have an exit sign posted at the time of the inspection.

Exit signs must be placed over each exit.

***Correction: An exit sign has been posted in room 228..**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

08/26/2023

Actual
Completion
Date:

10/26/2023

Status: **Corrected**

18. Are exits and exit corridors maintained in a safe manner? 61:15:05:05; 61:15:06:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths maintained at 36 inches or more; exits cannot be obstructed.

Corrections To Be Made:

The exit corridor to exit C was partially obstructed by classroom materials.

Exits may not be obstructed.

***Correction: The classroom materials were moved from the exit corridor.
The program will ensure that all exits remain unblocked.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

08/24/2023

Actual
Completion
Date:

08/23/2023

Status: **Corrected**

TAYLOR FECHNER

Provider Signature

08/23/2023

Date

Todd Lowe

Inspector Signature

08/23/2023

Date