

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **RENNBERG ELEMENTARY CLC** City: **Renner**

Provider Number: **018043140**

Inspector: **Todd Lowe**

Date of Inspection: **08/23/2023**

Time of Inspection: **3:32 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

18. Are exits and exit corridors maintained in a safe manner? 61:15:05:05; 61:15:06:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths maintained at 36 inches or more; exits cannot be obstructed.

Corrections To Be Made:

Corridor to Exit D by the Gym was restricted due to the storage of garbage cans.

Exits must be maintained unobstructed.

***Correction: Corridor has been cleared.**

Agency Action:

Compliance Plan

Suggested
Completion
Date:

08/24/2023

Actual
Completion
Date:

09/14/2023

Status: **Corrected**

TAYLOR FECHNER

Provider Signature

08/23/2023

Date

Todd Lowe

Inspector Signature

08/23/2023

Date