

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Central Downtown Childrens Center**

City: **Sioux Falls**

Provider Number: **018043172**

Inspector: **Patrick Waltman**

Date of Inspection: **12/02/2024**

Time of Inspection: **10:29 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

17. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05; 61:15:06:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p>At the time of inspection, the exit and emergency lighting on the South and West exit of the chapel did not have functioning batteries.</p> <p>The program will place new batteries to the emergency exit lighting and ensure the functionality of the system.</p> <p>The program installed new batteries and provided documentation ensuring the systems functionality.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">12/17/2024</td> <td style="text-align: center;">12/13/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	12/17/2024	12/13/2024
Suggested Completion Date:	Actual Completion Date:				
12/17/2024	12/13/2024				

21. Are portable fire extinguishers charged, operable, and inspected annually by a qualified service technician? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

<p>Corrections To Be Made:</p> <p>At the time of inspection, documentation for the annual fire extinguisher inspection was not available.</p> <p>The program will ensure the fire extinguisher is serviced by a qualified technician annually.</p> <p>The program supplied documentation of annual inspection for the fire extinguisher.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">12/17/2024</td> <td style="text-align: center;">12/10/2024</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	12/17/2024	12/10/2024
Suggested Completion Date:	Actual Completion Date:				
12/17/2024	12/10/2024				

Jennie Smithback

Provider Signature

12/02/2024

Date

Patrick Waltman

Inspector Signature

12/02/2024

Date