

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **GIMME-A-BREAK**

City: **Sioux Falls**

Provider Number: **018043178**

Inspector: **Todd Lowe**

Date of Inspection: **08/07/2023**

Time of Inspection: **11:12 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

5. In Licensed Programs caring for 21 or More Children - Is a fire alarm system inspected and serviced annually by a qualified service technician? 61:15:01:01

Corrections To Be Made:

The fire alarm system is a shared system for the building and the most current inspection that was located on the fire alarm panel was April of 2022. Contact the building owners to affirm the last inspection and update as needed.

A fire alarm system needs to be inspected and serviced annually by a qualified service technician.

Verification of the fire alarm system was been provided to OLA.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

08/27/2023

Actual
Completion
Date:

08/21/2023

Status: **Corrected**

Amanda McGregor

Provider Signature

08/07/2023

Date

Todd Lowe

Inspector Signature

08/07/2023

Date