

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Apple Tree West**

City: **Sioux Falls**

Provider Number: **018043200**

Inspector: **Todd Lowe**

Date of Inspection: **02/06/2024**

Time of Inspection: **10:37 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

18. Are exits and exit corridors maintained in a safe manner? 61:15:05:05; 61:15:06:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths maintained at 36 inches or more; exits cannot be obstructed.

Corrections To Be Made:

Two exits were not maintained in a safe manner.

A day care center or each level of a day care center where the occupant load exceeds ten must have at least two remote exits that meet the requirements set forth in chapter 10 of the International Building Code, 2015 edition.

Correction: Both exits were cleared of any obstructions and maintained in a safe manner.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

02/06/2024

Actual
Completion
Date:

02/06/2024

Status: **Corrected Immediately**

B. Environmental Health

58. Is the playground equipment installed according to the manufacturer ' s instructions and in good repair? 67:42:17:35

Corrections To Be Made:

A piece of the program's playground equipment was not in good repair.

Playgrounds for all child care settings must be safe, in good repair, and free of debris, trash, and weeds. Playground equipment must be installed according to the manufacturer's instructions and maintained in good repair.

Correction: All playground equipment was installed according to the manufacturer's instructions and in good repair.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

02/06/2024

Actual
Completion
Date:

02/06/2024

Status: **Corrected Immediately**

C. Food Service

67. Is there a dishwasher or a 3-compartment sink available for washing, rinsing, and sanitizing?
67:42:17:25 NOTE: Centers serving 20 or less children, may use a 2-compartment sink and a tub for sanitizing.

Corrections To Be Made:	Agency Action:	
The dishwasher was not working properly at the time of the inspection.	Compliance Plan	
Dishwashing can be done using a dishwasher or a three-compartment dishwashing process that includes washing in a hot detergent solution, rinsing in clear warm water, and sanitizing with a chemical sanitizing agent.	Suggested Completion Date:	Actual Completion Date:
Correction: The sanitation pump was fixed and is working properly.	02/06/2024	02/09/2024
	Status: Corrected	

Amy Hauff
Provider Signature

02/06/2024
Date

Todd Lowe
Inspector Signature

02/06/2024
Date