

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Stepping Stones**

City: **Yankton**

Provider Number: **019522405**

Inspector: **Stacy Wildermuth**

Date of Inspection: **09/24/2024**

Time of Inspection: **8:30 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

5. In Licensed Programs caring for 21 or More Children - Is a fire alarm system inspected and serviced annually by a qualified service technician? 61:15:01:01

Corrections To Be Made:	Agency Action:	
Fire alarm system has not been inspected since March 2023.	Compliance Plan	
The fire alarm system needs to be inspected/serviced yearly.	Suggested Completion Date:	Actual Completion Date:
Verification of a completed inspection was received.	10/01/2024	10/03/2024
	Status: Corrected	

Hollie Pearson

Provider Signature

09/24/2024

Date

Stacy Wildermuth

Inspector Signature

09/24/2024

Date