

**Facility Safety Inspection
Fire & Life Safety / Environmental Health
Before & After School Center - Non-School Location
Compliance Plan**

Provider's Name: **Snicklefritz South Kids Club**

City: **Harrisburg**

Provider Number: **018042326**

Inspector: **Sarah Boese**

Date of Inspection: **06/28/2023**

Time of Inspection: **12:31 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

10. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05

NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

The exit signs above both doors were not operational.

Exit signs must be either illuminated from the inside or outside, or be self-luminous.

The provider replaced the batteries of the exit signs to ensure they are all operational.

Agency Action:

Compliance Plan

| Suggested Completion Date: | Actual Completion Date: |
|----------------------------|-------------------------|
| 07/19/2023 | 07/20/2023 |
| Status: Corrected | |



Provider Signature

Karlie Dubro

Name

06/28/2023

Date



Inspector Signature

Sarah Boese

Name

06/28/2023

Date