

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Marion Bear Care**

City: **Marion**

Provider Number: **014512632**

Inspector: **Stacy Wildermuth**

Date of Inspection: **11/22/2024**

Time of Inspection: **12:45 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

23. Is there a carbon monoxide detector installed according to the manufacturer's directions if there is a furnace or appliances utilizing fossil fuels such as propane, natural, gas, etc.? 61:15:01:01

Corrections To Be Made:

Carbon monoxide detector was not available during inspection.

Carbon monoxide detectors are required in facilities that use fossil fuels.

It was verified that a detector was installed.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
----------------------------------	-------------------------------

12/22/2024	12/06/2024
-------------------	-------------------

Status: **Corrected**

24. NEW PROGRAMS: Are all requirements identified in the floor plan review letters issued by the Fire Marshall's Office and the Dept. of Health completed? Does facility layout match the approved floor plan? 67:42:17:02

Corrections To Be Made:

Carbon monoxide detector was not available during inspection.

The Fire Marshal's letter indicated that a carbon monoxide detector would be required for facilities that use fossil fuels.

It was verified that a detector was installed.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
----------------------------------	-------------------------------

12/22/2024	12/06/2024
-------------------	-------------------

Status: **Corrected**



Provider Signature

Rita Schmidt

Name

11/22/2024

Date



Inspector Signature

Stacy Wildermuth

Name

11/22/2024

Date