

Provider required to post this report.

Facility Safety Fire & Life Safety / Environmental Health Compliance Plan

Provider's Name: **Playpens N Puzzles Daycare**

City: **Pierre**

Provider Number: **010605976**

Inspector: **Chad Wrightson**

Date of Inspection: **12/10/2024**

Time of Inspection: **9:57 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. Fire and Life Safety

21. Are portable fire extinguishers charged, operable, and inspected annually by a qualified service technician? 61:15:05:10
NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher.
One near food preparation.

Corrections To Be Made:

An annual inspection was not complete on a fire extinguisher. Last inspection date was 01/2023.

All portable fire extinguishers must be charged, operable and inspected annually by a qualified service technician.

Verification received.

Agency Action:

Compliance Plan

Suggested Completion Date:	Actual Completion Date:
----------------------------------	-------------------------------

01/01/2025	12/21/2024
------------	------------

Status: **Corrected**



Provider Signature

Lindsey

Name

12/10/2024

Date



Inspector Signature

Chad Wrightson

Name

12/10/2024

Date